



Dear Customer,

The Springfield Water and Sewer Commission is pleased to issue our Annual Water Quality Report. The report talks about your drinking water, shows test results for 2005, and confirms that your water meets the requirements for safe drinking water established by state and federal standards.

Please read this report carefully and share the information with everyone who resides at your property. If you have any questions or if you need extra copies, please contact us at 413-787-6060.

Apreciado Cliente:

La Comisión de Acueductos y Alcantarillados se alegra en presentar a usted nuestro reporte anual de la calidad del agua. Este reporte habla acerca del agua que usted toma. Pruebas muestran los resultados para el 2005, confirman que el agua alcanza los requerimientos de la seguridad en el agua potable establecidos por los estándares federales y estatales.

Por favor lea este reporte cuidadosamente y comparta esta información con todos los que residen en su propiedad. Si tiene alguna pregunta o necesita copias extras, por favor llámenos al 413-787-6060.


La sección en español comienza en la página 7.

Commissioners

William E. Leonard, Chairman
Carmen E. Serrano-Gerena, Commissioner
Daniel Rodriguez, Commissioner

Contact Information/Información Sobre Contactos

- 💧 Billing Questions and Customer Service/Preguntas sobre facturas y Servicios al Consumidor: 413-787-6060
- 💧 Emergency/Emergencias: 413-787-6206
- 💧 Meter replacement or repair/Reemplazo o reparación del contador: 413-787-6206
- 💧 New Service or service replacement information/Nuevo servicio o información para reemplazo de servicio: 413-787-6060
- 💧 Public Information/Información Pública: 413-787-6256 Kathy Pedersen ext.111
- 💧 Email/Internet: info@waterandsewer.org
- 💧 Web Site/Internet: www.waterandsewer.org





The Springfield Water and Sewer Commission provides this report to meet Federal and State Safe Drinking Water Act Requirements. The report is developed in-house and each copy costs only 26 cents to print and mail.

About Your Water

The drinking water produced by the Springfield Water and Sewer Commission originates from a surface water supply, the Cobble Mountain Reservoir, located in Western Massachusetts. The water is filtered through slow or rapid sand filtration, treated to inhibit corrosion of home plumbing, adjusted for pH, and disinfected with chlorine before it is distributed to your home or business. Clean water is supplied at an annual average of 37 million gallons per day to

Springfield and the surrounding communities of Agawam, East Longmeadow, Longmeadow and Ludlow.

In order to ensure that tap water is safe to drink, the U.S. Environmental Protection Agency (EPA) prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water that must provide the same protection for public health. 💧

Important Information from EPA and the Department of Environmental Protection (DEP)

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and in some cases radioactive material. It can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include the following:

microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, humans, and wildlife;

inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming;

pesticides and herbicides, that may come from a variety of sources such as agricultural, urban stormwater runoff, and residential uses;

organic chemical contaminants, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and

radioactive contaminants, that can be naturally-occurring or the result of oil and gas production and mining activities.

Drinking Water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA Safe Drinking Water Hotline at 1-800-426-4791. 💧



Cobble Mountain Reservoir



Source Water Assessment

The Department of Environmental Protection conducted a Source Water Assessment to provide baseline data about the quality of the reservoir water before it is treated, filtered, and distributed. This is important because it identifies the origins of contaminants within the watershed area and indicates the susceptibility of our water system to such contaminants. A copy of the Assessment may be obtained by contacting the Commission at 413-787-6256. 💧

Special Health Information

Some people may be more vulnerable to contaminants in drinking water than the general population as a whole.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and some infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control and Prevention (CDC) guidelines on lowering the risk of infection by cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline at 1-800-426-4791. 💧

Lead and Copper

The Commission's source water and the water in the distribution system is lead free. However, some older homes may have lead soldered joints or lead or copper pipes as part of the plumbing. The lead may dissolve into the water while the water is not moving, generally overnight or other times when the water is not used for several hours.

Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested. Flush your tap for 30 seconds to 2 minutes before using tap water to reduce lead content.

For more information on lead in drinking water contact the Springfield Water and Sewer Commission or Safe Drinking Water Hotline at 1-800-426-4791. 💧



Lead and Copper Sampling Table

Substance	MCLG	MCL	90th Percentile Sample	Sampling Sites Exceeding the Action Level	Violation	Major Sources in Drinking Water
Copper (ppm)	1.3	AL = 1.3	0.079	1 out of 269	No	Corrosion of household plumbing systems
Lead (ppb)	0	AL = 15.0	17.0	28 out of 269	No*	

AL = Action Level - The concentration of a contaminant that if exceeded, triggers treatment or other requirements that a water system must follow.

MCL = Maximum Contaminant Level - The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology.

MCLG = Maximum Contaminant Level Goal - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety.

*The Action Level for lead was exceeded in 2005. This is not a drinking water violation, but does require us to take action. Public education notices were mailed to all customers and distributed to community organizations in December 2005. If you want a copy of the lead public education notice, please contact us. Two rounds of lead sampling will be conducted in 2006 and evaluation of Springfield's corrosion control program was completed in March 2006.

Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.



Water Quality Information Table

The table shows only the detections as a result of our more than 51,000 water quality tests, which were completed in 2005. The Commission's state certified laboratory analyzes water samples daily. Private certified laboratories are also utilized to insure that the water supplied to you meets or is better than all state and federal standards.

The data below represents finished water in the distribution system.

Public Water Supply Identification #1281000

Organics						
Substance	Ideal Goal (MCLG)	Maximum Contaminant Level (MCL)	Annual Running Average	Range Detected at Individual Sampling Sites	Violation	Major Sources in Drinking Water
TThms (ppb) (Total Trihalomethanes)	N/A	80 (Annual running average)	64	47 - 97	No	By-product of drinking water chlorination
HAA5s (ppb) Total Haloacetic Acids	N/A	60 (Annual running average)	32	7 - 55	No	
Disinfectants						
Substance	MRDLG	MRDL	Annual Running Average	Range Detected at Individual Sampling Sites	Violation	Major Sources in Drinking Water
Residual Chlorine (ppm)	4.0	4.0	0.07	0.01 - 0.48	No	Water additive used to control microbes
Inorganics						
Substance	MCLG	MCL	Highest Detected Level		Violation	Major Sources in Drinking Water
Nitrate (ppm)	10	10	0.05	N/A	No	Natural deposits, stormwater, fertilizer run-off
Barium (ppm)	2	2	0.009	N/A	No	Common mineral in nature
Microbiological						
Substance	MCLG	MCL	Highest Single Measurement Detected	Lowest Monthly Percent	Violation	Major Sources in Drinking Water
Total Coliform	0	5% of Monthly Samples	3.5%	N/A	No	Human and animal fecal waste
Turbidity *						
Substance	MCLG	MCL	Highest Single Measurement Detected	Lowest Monthly Percent	Violation	Major Sources in Drinking Water
Rapid Sand Filtration (NTU) **	N/A	TT	0.31	100%	No	Soil run-off
Slow Sand Filtration (NTU) ***	N/A	TT	0.16	100%	No	
Unregulated ****						
Substance	ORSG	MCL	Single Measurement		Violation	Major Sources in Drinking Water
Sodium (ppm)	20	None	13.0	N/A	No	Natural deposits
Substance	SMCL	MCL	Single Measurement		Violation	Major Sources in Drinking Water
Sulfate (ppm)	250	None	4.8	N/A	No	Natural deposits

Glossary

MCL = Maximum Contaminant Level - The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology.

MCLG = Maximum Contaminant Level Goal - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety.

MRDL = Maximum Residual Disinfectant Level - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG - Maximum Residual Disinfectant Level Goal - The level of a drinking water disinfectant below which there is no known expected risk to health. MRDLG's do not reflect the benefits of the use of disinfectants to control microbial contaminants.

N/A = Not Applicable

NTU = Nephelometric Turbidity Units - A numeric value indicating the cloudiness of water.

ORSG = Massachusetts Office of Research and Standards Guideline - The concentration of a chemical in drinking water, at or below which, adverse health effects are unlikely to occur after chronic (lifetime) exposure. If exceeded, it serves as an indicator of the potential need for further action.

ppb = parts per billion

ppm = parts per million

SMCL = Secondary Maximum Contaminant Level - These standards are developed to protect the aesthetic qualities of drinking water and are not health based.

TT = Treatment Technique - A required process intended to reduce the level of a contaminant in drinking water.

*** Turbidity** - A measure of the cloudiness of water. We monitor turbidity because it is a good indicator of the effectiveness of our filtration system.

**** Rapid Sand Filtration** - The turbidity level of the filtered water shall be less than or equal to 0.3 NTU in 95% of the measurements taken each month and shall not exceed a maximum of 1.0 NTU in any single measurement.

***** Slow Sand Filtration** - The turbidity level of the filtered water shall be less than or equal to 1.0 NTU in 95% of the measurements taken each month and shall not exceed a maximum of 5.0 NTU in any single measurement.

****** Unregulated Contaminants** - They are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining their occurrence in drinking water and whether future regulation is necessary. Unregulated contaminant monitoring results are available by contacting Kathy Pedersen at: 413-787-6256 Ext. 111.



Investing in our future

In Fiscal Year 2005 the Commission continued a five-year infrastructure renewal and replacement program to improve the reliability of our underground water delivery system, sewer collection system, metering capability, heightened security needs and water treatment plant.

In fiscal year 2005, the Commission installed:

- ◆ 9,546 feet of new water main pipe
- ◆ 9,121 feet of replacement water main pipe
- ◆ 31 new hydrants
- ◆ 93 hydrants repaired
- ◆ 75 hydrants replaced
- ◆ 6 hydrants removed or relocated
- ◆ 122 gate valves replaced
- ◆ 8,635 new residential water meters
- ◆ 174 new commercial water meters
- ◆ 303 new water services
- ◆ 299 water services repaired or relocated
- ◆ 4,855 feet of new sewer main




Cross Connection Control Program

A cross connection is formed at any point where a drinking water line connects to equipment, a system containing chemicals, or water of questionable quality, and backflow may occur into the drinking water line.

Some examples of where cross connections may occur are at boilers, air conditioning systems, fire sprinkler systems, irrigation systems, laboratory equipment, plating tanks, or chemical vats.

If you are an owner of industrial, institutional or commercial property you must have your facility's internal plumbing surveyed for cross connection hazards and install proper backflow devices or eliminate cross connections entirely. For more information, contact the Commission's Cross Connection Control Program at 413-787-6206. ♦



What is a Cross Connection?

A simple example is the common garden hose connected to a tap with the end of the hose attached to a container with garden chemicals. The ordinary garden hose is the most common offender because it can easily be connected to the potable water supply and used for a variety of potentially dangerous applications.

Water Facts

Water's Role in the Body

Water helps nearly every part of the human body function efficiently. Considering that our bodies are almost two-thirds water, it is important to understand water's role in healthy lifestyles. The following are just some of the things water does in the body:

- ◆ The brain is 75% water
- ◆ Water is required for breathing
- ◆ Regulates body temperature
- ◆ Carries nutrients and oxygen to all cells in the body
- ◆ Blood is 92% water
- ◆ Moistens oxygen for breathing
- ◆ Protects and cushions vital organs
- ◆ Helps to convert food into energy
- ◆ Helps body absorb nutrients
- ◆ Removes waste
- ◆ Bones are 22% water
- ◆ Muscles are 75% water
- ◆ Cushions joints

Source: Dr. Dave MD and Dr. Dee Ph'D
"13 Things Water Does in the Body"
(Compiled from a Iowa State University Study)



Did You Know?



Little leaks add up in a hurry. A faucet drip or invisible toilet leak that totals only two tablespoons a minute comes to 15 gallons a day. That's 105 gallons a week and 5,460 wasted gallons of water a year.

Did You Know?



Some people thoughtlessly flush away tissues and other bits of trash in the toilet. Using a wastebasket instead, will save all those gallons of water that otherwise go wastefully down the drain.

IMPORTANT WATER INFORMATION IMPORTANTE INFORMACIÓN SOBRE EL AGUA

This report contains important information about your community's water quality. Please have it translated.

Este informe contiene información importante sobre la calidad del agua en su comunidad. Por favor pida que alguien se lo traduzca.

Le rapport contient des informations concernant la qualite de l'eau de votre communaute. Faites-le traduire, ou parlez-en a un ami qui le comprend bien.

O relatorio contem informacoes importantes sobre a qualidade da agua da comunidade. Traduza-o ou peca ajuda de uma pessoa amiga para ajuda-lo a entender melhor.

Questo rapporto contiene informazioni importanti della qualita' d'acqua della vostra comunita'. Traducetelo al piu' presto possibile o parlate con unamico che lo capisce benissimo.

Sprawozdanie zawiera wazne informacje na temat jakosci wody w twojej miejscowosci. Popros kogos o przetlumaczenie go lub porozmawiaj z osoba ktora je dobrze rozumie.

Đây là những thông tin quan trọng nói về phẩm chất của nước dùng trong cộng đồng địa phương của bạn. Xin hãy chuyển ngữ các thông tin này cho quý vị.



[Pay Your Water and Sewer Bill On-Line at www.waterandsewer.org](http://www.waterandsewer.org)

[Pague su factura de agua por correo electronico al www.waterandsewer.org](http://www.waterandsewer.org)

Our
Drinking Water
for
2005

Borden Brook Reservoir



Springfield Water and Sewer Commission

*Annual Water Quality Report
Informe Anual de la Calidad del Agua*